

UCB F 12.02 2012-02



## CERTIFICATE

No. U8V 12 05 54214 024

Allegro MicroSystems, Inc. **Holder of Certificate:** 

> 955 Perimeter Road Manchester NH 03103

USA

**Production** 54214

Facility(ies):

**Certification Mark:** 



Current sensor / Voltage sensor **Product:** 

**Hall Effect Current Sensor** 

Model(s): ACS756, ACS758, ACS759

**Parameters:** ACS756

990 Vpk or DC,700 Vrms Rated Working Voltage:

Transient Sensed Current: 200 A Max. 3000 V AC Isolation Voltage: See Certificate Attachment for Additional Ratings

CAN/CSA C22.2 No. 60950-1:2007 **Tested** 

UL 60950-1:2007 according to: EN 60950-1/A1:2010

The product was voluntarily tested according to the relevant safety requirements noted above. It can be marked with the certification mark above. The mark must not be altered in anyway. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC Guide 67. Certification is based on the TÜV SÜD "Testing and Certification Regulations".

090-1106414-200 Test report no .:

Date, 2012-06-06

Page 1 of 2



JCB\_F\_12.02 2012-02

## Attachment to Certificate U8V 12 05 54214 024



Allegro MicroSystems, Inc. 955 Perimeter Road Manchester, NH 03103-3353, USA

## Rating Information:

ACS756: Rated isolation voltage: 3000 Vrms for 1 minute Working Voltage for Basic/Supplemental isolation at 990Vpk or DC, 700 Vrms

ACS758, ACS759: Rated isolation voltage: 4800 Vrms for 1 minute Working Voltage for Double/Reinforced isolation at 636Vpk or DC, 450Vrms Working Voltage for Basic isolation at 990Vpk or DC, 700 Vrms

Transient Sensed Current: 200A max. (all models)

Test Report No: 090-1106414-200

Date, 2012-06-06

U8V 12 05 54214 024

